


Quality of Water in the Vaal Barrage Reservoir

Date Sampled 18 September 2019



Interpretation of the results obtained from water samples collected at the respective sample points (refer map above).

Escherichia coli (E.coli) Predicted symptoms include: Skin irritations, infections & intestinal disorders*	E.coli counts per 100ml at sample points									
	1	2	3	4	5	6	7	8	9	10
	This Week	99	6	488	6,160	1,986	3	4	54,750	816,400
Last Week	126	10	866	3,450	66	649	23	8,600	1,046,200	727
Guideline	Low risk of gastrointestinal disorders <i>E.coli</i> < 130 counts/100ml			Slight risk of gastrointestinal disorders <i>E.coli</i> 130 - 200 counts/100ml		Significant risk of gastrointestinal disorders <i>E.coli</i> 200 - 400 counts/100ml		High risk of gastrointestinal disorders <i>E.coli</i> > 400 counts/100ml		

Blue Green Algae Predicted symptoms include: Skin irritations, infections & intestinal disorders*	Blue Green algae counts at sample points									
	1	2	3	4	5	6	7	8	9	10
	This Week	65	< 40	344	108	< 40	323	< 40	2,153	861
Last Week	< 40	431	2,081	969	646	646	1,614	3,229	72	1,399
Guideline	Low Risk Blue Green algae < 20,000 cells/ml			Moderate Risk Blue Green algae 20,000 - 100,000 cells/ml			High Risk Blue Green algae > 100,000 cells/ml			

Algal Pigments Predicted nuisance conditions include: Scums & smells	Algal pigments expressed as Chlorophyll-a levels at sample points									
	1	2	3	4	5	6	7	8	9	10
	This Week	3	24	3	153	394	126	279	143	57
Last Week	2	8	6	66	52	89	222	53	23	51
Guideline	Low Risk Chlorophyll-a < 15ug/l			Moderate Risk Chlorophyll-a 15 - 30ug/l			High Risk Chlorophyll-a > 30ug/l			

* If ingested. X Sample not received / no data available. Reports generated every Friday of the year.

DISCLAIMER: Although Rand Water has made every endeavour to make an accurate assessment of the parameters described above (based on published South African and international criteria), neither Rand Water, nor any of its officials, shall be responsible for any damage or health related problems that may result due to the use of the Vaal Barrage Reservoir for any purpose.