

Variables	Measured as	Ideal Catchment Background	Acceptable Management Target	Tolerable Interim Target	Unacceptable
<b>Physical</b>					
Conductivity	mS/m	< 45	45 - 70	70 - 120	> 120
Dissolved Oxygen (O <sub>2</sub> )	mg/l O <sub>2</sub>		> 6.0	5.0 - 6.0	< 5.0
pH	pH units	6.5 - 8.5			< 6.5; > 8.5
Suspended Solids	mg/l	< 20	20 - 30	30 - 55	> 55
<b>Organic</b>					
Chemical Oxygen Demand (COD)	mg/l	< 20	20 - 35	25 - 55	> 55
<b>Macro Elements</b>					
Aluminium (Al)	mg/l	< 0.3	0.3 - 0.4	0.4 - 0.5	> 0.5
Ammonia (NH <sub>4</sub> )	mg/l	< 0.1	0.1 - 1.5	1.5 - 5.0	> 5.0
Chloride (Cl)	mg/l	< 80	80 - 150	150 - 200	> 200
Fluoride (F)	mg/l	< 0.19	0.19 - 0.70	0.70 - 1.00	> 1.00
Iron (Fe)	mg/l	< 0.1	0.1 - 0.5	0.5 - 1.0	> 1.0
Magnesium (Mg)	mg/l	< 8	8 - 30	30 - 70	> 70
Manganese (Mn)	mg/l	< 0.2	0.2 - 0.5	0.5 - 1.0	> 1.0
Nitrate (NO <sub>3</sub> )	mg/l	< 0.5	0.5 - 3.0	3.0 - 6.0	> 6.0
Phosphate (PO <sub>4</sub> )	mg/l	< 0.2	0.2 - 0.4	0.4 - 0.6	> 0.6
Sodium (Na)	mg/l	< 70	70 - 100	100 - 150	> 150
Sulphate (SO <sub>4</sub> )	mg/l	< 150	150 - 300	300 - 500	> 500
<b>Bacteriological</b>					
<i>E. coli</i>	counts/100ml	< 130	130 - 200	200 - 400	> 400
<i>Faecal coliforms</i>	counts/100ml	< 126	126 - 1,000	1,000 - 10,000	> 10,000
<b>Biological</b>					
<i>Daphnia</i>	% survival	100	90 - 100	80 - 90	< 80