

Madibeng Municipality Water Quality Report - 1 Month

22 November 2017 to 22 December 2017 Date generated: 04 January 2018

Determinand	Measurement units	Risk	Required compliance to SANS 241: 2015 standard (%)	SANS 241: 2015 standard limits (1)	No of results	Achieved Compliance to SANS 241: 2015 Spec(%)	Descriptive statistics		
							Mean	Standard Deviation	Mean + 3 standard deviations
Microbiological determinands									
<i>E. coli</i>	(mpn per 100 mL)	Acute health	99.0%	0	32	100.0%	0	0.00	0
Total Coliforms	(mpn per 100 mL)	Operational	95.0%	10	32	100.0%	0	0.00	0
Heterotrophic Plate Count	(cfu per 1 mL)	Operational	95.0%	≤1000	32	100.0%	3	4.24	18
<i>Cryptosporidium spp</i> (5)	(org / 10 Litre)	Acute health	99.0%	0	16	100.0%	0	0.00	0
<i>Giardia spp</i> (5)	(org / 10 Litre)	Acute health	99.0%	0	16	100.0%	0	0.00	0
Somatic Coliphages (5)	(count per 10 mL)	Operational	95.0%	0	64	100.0%	0	0.00	0
Physical and Aesthetic determinands									
Colour	(mg / L as Pt-Co)	Aesthetic	95.0%	≤15	1	100.0%	5.00	not applicable	5.00
Conductivity	(mS / m)	Aesthetic	95.0%	≤170	32	100.0%	18.19	0.74	19.69
Total Dissolved Solids	(mg / L)	Aesthetic	95.0%	≤1200	32	100.0%	129.65	4.30	138.41
Turbidity	(NTU)	Operational	95.0%	≤1	32	100.0%	0.26	0.08	0.43
Turbidity	(NTU)	Aesthetic	95.0%	≤5	32	100.0%	0.26	0.08	0.43
pH	(pH units)	Operational	95.0%	≥ 5 to ≤ 9.7	32	100.0%	7.89	0.14	8.13
Chemical Properties									
Macro determinands									
Ammonia	(mg / L as N)	Aesthetic	95.0%	≤1.5	32	100.0%	0.27	0.13	0.63
Chloride	(mg / L as Cl)	Aesthetic	95.0%	≤300	2	100.0%	11.50	0.71	11.99
Free chlorine (2)	(mg / L as Cl ₂)	Chronic health	97.0%	≤5	29	100.0%	0.18	0.27	0.98
Monochloramine (3)	(mg / L as Cl ₂)	Chronic health	97.0%	≤4.1	29	100.0%	0.91	0.37	1.53
Fluoride	(mg / L as F)	Chronic health	97.0%	≤1.5	2	100.0%	0.19	0.00	0.19
Nitrate	(mg / L as N)	Acute health	99.0%	≤11	32	100.0%	0.44	0.00	0.44
Nitrite	(mg / L as N)	Acute health	99.0%	≤0.9	32	96.9%	0.22	0.31	1.31
Combined nitrate plus nitrite (7)	(mg / L as N)	Acute health	99.0%	≤1	32	96.9%	0.28	0.34	1.50
Residual disinfectant (4)	(mg / L)	Operational	95.0%	≥0.1 Sum of Free and Monochloramine	29	100.0%	1.09	0.27	1.64
Sodium	(mg / L as Na)	Aesthetic	95.0%	≤200	1	100.0%	8.40	not applicable	8.40
Sulphate	(mg / L as SO ₄)	Aesthetic	95.0%	≤250	2	100.0%	13.50	0.71	13.99
Sulphate	(mg / L as SO ₄)	Acute health	99.0%	≤500	2	100.0%	13.50	0.71	13.99
Zinc	(mg / L as Zn)	Aesthetic	95.0%	≤5	1	100.0%	0.02	not applicable	0.02
Micro determinands									
Aluminium	(µg / L as Al)	Operational	95.0%	≤300	1	100.0%	28.00	not applicable	28.00
Antimony	(µg / L as Sb)	Chronic health	97.0%	≤20	1	100.0%	0.50	not applicable	0.50
Arsenic	(µg / L as As)	Chronic health	97.0%	≤10	1	100.0%	1.10	not applicable	1.10
Barium	(µg / L as Ba)	Chronic health	97.0%	≤700	1	100.0%	34.00	not applicable	34.00
Boron	(µg / L as B)	Chronic health	97.0%	≤2400	1	100.0%	25.00	not applicable	25.00
Cadmium	(µg / L as Cd)	Chronic health	97.0%	≤3	1	100.0%	2.50	not applicable	2.50
Chromium (Total)	(µg / L as Cr)	Chronic health	97.0%	≤50	1	100.0%	15.00	not applicable	15.00
Copper	(µg / L as Cu)	Chronic health	97.0%	≤2000	1	100.0%	10.00	not applicable	10.00
Cyanide (Recoverable)	(µg / L as CN)	Acute health	99.0%	≤200	1	100.0%	5.00	not applicable	5.00
Iron	(µg / L as Fe)	Chronic health	97.0%	≤2000	1	100.0%	17.00	not applicable	17.00
Iron	(µg / L as Fe)	Aesthetic	95.0%	≤300	1	100.0%	17.00	not applicable	17.00
Lead	(µg / L as Pb)	Chronic health	97.0%	≤10	1	100.0%	0.20	not applicable	0.20
Manganese	(µg / L as Mn)	Chronic health	97.0%	≤400	1	100.0%	10.00	not applicable	10.00
Manganese	(µg / L as Mn)	Aesthetic	95.0%	≤100	1	100.0%	10.00	not applicable	10.00
Mercury	(µg / L as Hg)	Chronic health	97.0%	≤6	1	100.0%	0.80	not applicable	0.80
Nickel	(µg / L as Ni)	Chronic health	97.0%	≤70	1	100.0%	10.00	not applicable	10.00
Selenium	(µg / L as Se)	Chronic health	97.0%	≤40	1	100.0%	0.50	not applicable	0.50
Uranium	(µg / L as U)	Chronic health	97.0%	≤30	1	100.0%	0.20	not applicable	0.20
Organic determinands									
Total Organic Carbon	(mg / L)	Chronic health	97.0%	≤10	1	100.0%	4.00	not applicable	4.00
Phenols as C ₆ H ₅ OH	(µg / L)	Aesthetic	95.0%	≤10	1	100.0%	5.00	not applicable	5.00
Chloroform - CHCl ₃	(µg / L)	Chronic health	97.0%	≤300	1	100.0%	38.00	not applicable	38.00
Bromoform - CHBr ₃	(µg / L)	Chronic health	97.0%	≤100	1	100.0%	0.50	not applicable	0.50
Dibromochloromethane - CHBr ₂ Cl	(µg / L)	Chronic health	97.0%	≤100	1	100.0%	1.20	not applicable	1.20
Bromodichloromethane - CHBrCl ₂	(µg / L)	Chronic health	97.0%	≤60	1	100.0%	13.00	not applicable	13.00
Combined trihalomethanes (8)	(µg / L)	Chronic health	97.0%	≤1	1	100.0%	0.36	not applicable	0.36
Total Microcystin (5)	(µg / L)	Chronic health	97.0%	≤1	16	100.0%	0.31	0.00	0.31
For monitoring/reporting purposes only (6)									
Calcium	(mg / L as Ca)	Aesthetic	not applicable	≤150	1	100.0%	19.00	not applicable	19
Hardness	(mg / L as CaCO ₃)	Operational	not applicable	≥ 20 to ≤ 200	1	100.0%	67.91	not applicable	67.91
Magnesium	(mg / L as Mg)	Aesthetic	not applicable	≤70	1	100.0%	5.90	not applicable	5.90
Potassium	(mg / L as K)	Aesthetic	not applicable	≤50	1	100.0%	4.10	not applicable	4.10
Rand Water Risk Determinands (RWRD)									
Odour	TON	RWRD	95.0%	≤2	14	100.0%	1.00	0.00	1.00
Taste	FTN	RWRD	95.0%	≤2	14	100.0%	1.00	0.00	1.00

Risk	Required compliance to SANS 241: 2015 standard	Overall Compliance-SANS 241
Acute health microbiological	99.00%	100.00%
Acute health chemical	99.00%	97.98%
Chronic health	97.00%	100.00%
Aesthetic	95.00%	100.00%
Operational	95.00%	100.00%

- Notes:**
- (1) Specification date of effect : 1 July 2016
 - (2) Free chlorine : Results from chloraminated system
 - (3) Monochloramine : Results are from the chloraminated systems
 - (4) Residual disinfectant : Results from chloraminated system
 - (5) Measured at water treatment works exit points
 - (6) Customer request: Results not included in the risk indices compliance calculations
 - (7) (NO₂/0.9 + NO₃/11)
 - (8) (CHCl₃/300 + CHBr₃/100 + CHBr₂Cl/100 + CHBrCl₂/60)