

**Victor Khanye Municipality (Delmas System) Water Quality Report - 1 Month**

24 October 2017 to 21 November 2017 Date generated: 05 December 2017

Determinand	Measurement units	Risk	Required compliance to SANS 241: 2015 standard (%)	SANS 241: 2015 standard limits (1)	No of results	Achieved Compliance to SANS 241: 2015 Spec(%)	Descriptive statistics		
							Mean	Standard Deviation	Mean + 3 standard deviations
<b>Microbiological determinands</b>									
<i>E. coli</i>	(mpn per 100 mL)	Acute health	99.0%	0	23	100.0%	0	0.00	0
Total Coliforms	(mpn per 100 mL)	Operational	95.0%	10	23	100.0%	0	0.00	0
Heterotrophic Plate Count	(cfu per 1 mL)	Operational	95.0%	≤1000	23	100.0%	2	3.27	12
<i>Cryptosporidium spp</i> (5)	(org / 10 Litre)	Acute health	99.0%	0	14	100.0%	0	0.00	0
<i>Giardia spp</i> (5)	(org / 10 Litre)	Acute health	99.0%	0	14	100.0%	0	0.00	0
Somatic Coliphages (5)	(count per 10 mL)	Operational	95.0%	0	72	100.0%	0	0.00	0
<b>Physical and Aesthetic determinands</b>									
Colour	(mg / L as Pt-Co)	Aesthetic	95.0%	≤15	2	100.0%	5.00	0.00	5.00
Conductivity	(mS / m)	Aesthetic	95.0%	≤170	23	100.0%	18.13	0.87	19.00
Total Dissolved Solids	(mg / L)	Aesthetic	95.0%	≤1200	23	100.0%	129.31	5.06	134.38
Turbidity	(NTU)	Operational	95.0%	≤1	23	100.0%	0.32	0.06	0.47
Turbidity	(NTU)	Aesthetic	95.0%	≤5	23	100.0%	0.32	0.06	0.47
pH	(pH units)	Operational	95.0%	≥ 5 to ≤ 9.7	23	100.0%	7.72	0.08	7.87
<b>Chemical Properties</b>									
<b>Macro determinands</b>									
Ammonia	(mg / L as N)	Aesthetic	95.0%	≤1.5	23	100.0%	0.34	0.18	0.87
Chloride	(mg / L as Cl)	Aesthetic	95.0%	≤300	2	100.0%	10.50	0.71	10.99
Free chlorine (2)	(mg / L as Cl <sub>2</sub> )	Chronic health	97.0%	≤5	23	100.0%	0.20	0.33	1.33
Monochloramine (3)	(mg / L as Cl <sub>2</sub> )	Chronic health	97.0%	≤4.1	23	100.0%	1.00	0.47	1.67
Fluoride	(mg / L as F)	Chronic health	97.0%	≤1.5	2	100.0%	0.19	0.00	0.19
Nitrate	(mg / L as N)	Acute health	99.0%	≤11	23	100.0%	0.45	0.04	0.59
Nitrite	(mg / L as N)	Acute health	99.0%	≤0.9	23	100.0%	0.09	0.09	0.39
Combined nitrate plus nitrite (7)	(mg / L as N)	Acute health	99.0%	≤1	23	100.0%	0.14	0.11	0.47
Residual disinfectant (4)	(mg / L)	Operational	95.0%	≥0.1 Sum of Free and Monochloramine	23	100.0%	1.21	0.39	1.92
Sodium	(mg / L as Na)	Aesthetic	95.0%	≤200	2	100.0%	7.30	0.00	7.30
Sulphate	(mg / L as SO <sub>4</sub> )	Aesthetic	95.0%	≤250	2	100.0%	13.50	0.71	13.99
Sulphate	(mg / L as SO <sub>4</sub> )	Acute health	99.0%	≤500	2	100.0%	13.50	0.71	13.99
Zinc	(mg / L as Zn)	Aesthetic	95.0%	≤5	2	100.0%	0.02	0.00	0.02
<b>Micro determinands</b>									
Aluminium	(µg / L as Al)	Operational	95.0%	≤300	2	100.0%	33.00	4.24	35.94
Antimony	(µg / L as Sb)	Chronic health	97.0%	≤20	2	100.0%	0.50	0.00	0.50
Arsenic	(µg / L as As)	Chronic health	97.0%	≤10	2	100.0%	1.60	0.00	1.60
Barium	(µg / L as Ba)	Chronic health	97.0%	≤700	2	100.0%	39.50	0.71	39.99
Boron	(µg / L as B)	Chronic health	97.0%	≤2400	2	100.0%	25.00	0.00	25.00
Cadmium	(µg / L as Cd)	Chronic health	97.0%	≤3	2	100.0%	2.50	0.00	2.50
Chromium (Total)	(µg / L as Cr)	Chronic health	97.0%	≤50	2	100.0%	15.00	0.00	15.00
Copper	(µg / L as Cu)	Chronic health	97.0%	≤2000	2	100.0%	10.00	0.00	10.00
Cyanide (Recoverable)	(µg / L as CN)	Acute health	99.0%	≤200	2	100.0%	5.00	0.00	5.00
Iron	(µg / L as Fe)	Chronic health	97.0%	≤2000	2	100.0%	14.75	8.84	20.88
Iron	(µg / L as Fe)	Aesthetic	95.0%	≤300	2	100.0%	14.75	8.84	20.88
Lead	(µg / L as Pb)	Chronic health	97.0%	≤10	2	100.0%	0.20	0.00	0.20
Manganese	(µg / L as Mn)	Chronic health	97.0%	≤400	2	100.0%	10.00	0.00	10.00
Manganese	(µg / L as Mn)	Aesthetic	95.0%	≤100	2	100.0%	10.00	0.00	10.00
Mercury	(µg / L as Hg)	Chronic health	97.0%	≤6	2	100.0%	0.80	0.00	0.80
Nickel	(µg / L as Ni)	Chronic health	97.0%	≤70	2	100.0%	10.00	0.00	10.00
Selenium	(µg / L as Se)	Chronic health	97.0%	≤40	2	100.0%	0.50	0.00	0.50
Uranium	(µg / L as U)	Chronic health	97.0%	≤30	2	100.0%	0.20	0.00	0.20
<b>Organic determinands</b>									
Total Organic Carbon	(mg / L)	Chronic health	97.0%	≤10	2	100.0%	3.55	0.07	3.60
Phenols as C <sub>6</sub> H <sub>5</sub> OH	(µg / L)	Aesthetic	95.0%	≤10	3	100.0%	5.00	0.00	5.00
Chloroform - CHCl <sub>3</sub>	(µg / L)	Chronic health	97.0%	≤300	2	100.0%	43.00	1.41	43.98
Bromoform - CHBr <sub>3</sub>	(µg / L)	Chronic health	97.0%	≤100	2	100.0%	0.50	0.00	0.50
Dibromochloromethane - CHBr <sub>2</sub> Cl	(µg / L)	Chronic health	97.0%	≤100	2	100.0%	1.50	0.00	1.50
Bromodichloromethane - CHBrCl <sub>2</sub>	(µg / L)	Chronic health	97.0%	≤60	2	100.0%	13.00	0.00	13.00
Combined trihalomethanes (8)	(µg / L)	Chronic health	97.0%	≤1	2	100.0%	0.38	0.00	0.38
Total Microcystin (5)	(µg / L)	Chronic health	97.0%	≤1	14	100.0%	0.31	0.00	0.31
<b>For monitoring/reporting purposes only (6)</b>									
Calcium	(mg / L as Ca)	Aesthetic	not applicable	≤150	2	100.0%	13.00	0.00	13
Hardness	(mg / L as CaCO <sub>3</sub> )	Operational	not applicable	≥ 20 to ≤ 200	2	100.0%	50.67	0.74	51.18
Magnesium	(mg / L as Mg)	Aesthetic	not applicable	≤70	2	100.0%	5.25	0.21	5.40
Potassium	(mg / L as K)	Aesthetic	not applicable	≤50	2	100.0%	3.50	0.00	3.50
<b>Rand Water Risk Determinands (RWRD)</b>									
Odour	TON	RWRD	95.0%	≤2	10	100.0%	1.00	0.00	1.00
Taste	FTN	RWRD	95.0%	≤2	10	100.0%	1.00	0.00	1.00

Risk	Required compliance to SANS 241: 2015 standard	Overall Compliance-SANS 241
Acute health microbiological	99.00%	100.00%
Acute health chemical	99.00%	100.00%
Chronic health	97.00%	100.00%
Aesthetic	95.00%	100.00%
Operational	95.00%	100.00%

- Notes:**
- (1) Specification date of effect : 1 July 2016
  - (2) Free chlorine : Results from chloraminated system
  - (3) Monochloramine : Results are from the chloraminated systems
  - (4) Residual disinfectant : Results from chloraminated system
  - (5) Measured at water treatment works exit points
  - (6) Customer request: Results not included in the risk indices compliance calculations
  - (7) (NO<sub>2</sub>/0.9 + NO<sub>3</sub>/11)
  - (8) (CHCl<sub>3</sub>/300 + CHBr<sub>3</sub>/100 + CHBr<sub>2</sub>Cl/100 + CHBrCl<sub>2</sub>/60)