

Quality of Water in the Vaal Barrage Reservoir

Date Sampled 30 September 2020



Interpretation of the results obtained from water samples collected at the respective sample points (refer map above).

Escherichia coli (E.coli) Predicted symptoms include: Skin irritations, infections & intestinal disorders*	E.coli counts per 100ml at sample points									
	1	2	3	4	5	6	7	8	9	10
	This Week	231	35	579	30,760	770	26	199	1,414	51,720
Last Week	206	26	613	1,203	921	23	10	687	110,600	16
Guideline	Low risk of gastrointestinal disorders <i>E.coli</i> < 130 counts/100ml			Slight risk of gastrointestinal disorders <i>E.coli</i> 130 - 200 counts/100ml		Significant risk of gastrointestinal disorders <i>E.coli</i> 200 - 400 counts/100ml			High risk of gastrointestinal disorders <i>E.coli</i> > 400 counts/100ml	

Blue Green Algae Predicted symptoms include: Skin irritations, infections & intestinal disorders*	Blue Green algae counts at sample points									
	1	2	3	4	5	6	7	8	9	10
	This Week	< 40	121	223	724	241	241	1,148	3,982	234
Last Week	121	80	684	845	483	1,086	603	483	614	1,207
Guideline	Low Risk Blue Green algae < 20,000 cells/ml			Moderate Risk Blue Green algae 20,000 – 100,000 cells/ml			High Risk Blue Green algae > 100,000 cells/ml			

Algal Pigments Predicted nuisance conditions include: Scums & smells	Algal pigments expressed as Chlorophyll-a levels at sample points									
	1	2	3	4	5	6	7	8	9	10
	This Week	4	11	5	28	89	66	64	221	57
Last Week	9	7	6	5	23	50	62	134	24	197
Guideline	Low Risk Chlorophyll-a < 15ug/l			Moderate Risk Chlorophyll-a 15 - 30ug/l			High Risk Chlorophyll-a > 30ug/l			

* If ingested. X Sample not received / no data available. Reports generated every Friday of the year.

DISCLAIMER: Although Rand Water has made every endeavour to make an accurate assessment of the parameters described above (based on published South African and international criteria), neither Rand Water, nor any of its officials, shall be responsible for any damage or health related problems that may result due to the use of the Vaal Barrage Reservoir for any purpose. The values reported are only an indicator of water quality, and low numbers are no guarantee of safe water.