JOHANNESBURG WATER
WASTEWATER TREATMENT WORKS
Cumulatative Flow Weighted Compliance with Effluent Standards(2012-13)

															Cumulative
			2013	2013	2013	2013	2013	2013	2014	2014	2014	2014	2014	2014	Flow-weighted
			Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Compliance
Bushkoppie	Susp. Solids	</=15mg/l	74	81											
	COD	</=100mg/l	100	100											
	Ammonia (N)	</=2mg/l	71	55											
	Nitrate (N)	</=10mg/l	100	94											
	Phosphate (P)	</=1mg/l	94	100											
	E. coli	</=1000CFU/ml	92	100											
	Mean Compliance		88.5	100.0											
	Influent Flow	Ml/d	202	100											
	Influent Flow	Ml/m	6248	91											
Goudkoppies	Susp. Solids	</=15mg/l	94	84											
	COD	</=55mg/l	97	87											
	Ammonia (N)	</=2mg/l	90	84											
	Nitrate (N)	</=10mg/l	100	100											
	Phosphate (P)	</=1mg/l	100	94											
	E. coli	</=150CFU/ml	92	97											
	Mean Compliance		95.5	100.0											
	Influent Flow	Ml/d	135	80											
	Influent Flow	Ml/m	4174	91											
Olifantsvlei	Susp. Solids	</=15mg/l	100	100											
	COD	</=55mg/l	100	100											
	Ammonia (N)	</=2mg/l	100	100											
	Nitrate (N)	</=10mg/l	100	100											
	Phosphate (P)	</=1mg/l	100	100											
	E. coli	</=150CFU/ml	100	100											
	Mean Compliance		100.0	100.0											
	Influent Flow	Ml/d	167	100											
	Influent Flow	Ml/m	5169	100											
All works	Overall compliance (flow-weighted mean) %														#DIV/0!
	Influent Flow	Ml/d													#DIV/0!
	Influent Flow	Ml/m													#DIV/0!
Catchments	Klipriver														#DIV/0!