

Sample Points	Sample Point Description	Ammonia	Chloride	Fluoride	M-Alkalinity	Nitrate	Phosphate	Sulphate	Chemical Oxygen Demand	Conductivity	pH	E. coli
VE	Vaal River @ Ermelo 26°21'46.17"S 30° 6'31.15"E	0.27	11	0.33	69	0.47	<0.1	18	22	21	7.3	
		<0.2	9	0.31	60	0.80	0.22	34	22	21	7.2	
		<0.2	12	0.29	123	<0.1	0.21	17	15	33	7.9	
C-WITPUNTSRUIT	Witpuntspruit @ N2 near Camden 26°35'36.24"S 30° 05'46.84"E	0.20	10	0.23	31	0.10	0.10	14	22	14	6.9	
		0.78	12	0.25	<5	0.54	<0.1	182	<10	223	3.0	
		0.35	26	0.66	88	0.72	<0.2	62	24	82	5.9	
C-VAAL-DS_WITPT	Vaal River Downstream of Witpuntspruit 26°42'07.39"S 30° 04'58.08"E	0.68	19	0.79	<5	0.17	<0.1	403	13	292	3.0	
		0.39	11	0.58	78	0.68	<0.1	50	21	30	7.6	
		0.32	22	0.61	116	0.12	0.14	75	14	43	8.4	
VKV	Klein Vaal River @ Goedehoop 26°49'12.19"S 30° 8'12.00"E	0.20	<10	0.22	54	0.10	0.1	11	12	16	7.3	
		<0.2	21	0.35	65	1.22	0.20	89	18	20	7.4	
		0.39	18	0.44	121	1.63	0.14	43	18	36	8.4	
VRA	Rietspruit below Amersfoort 26°54'47.20"S 29°52'19.22"E	16.00	14	0.20	143	2.05	0.23	22	13	45	7.7	
		0.20	14	0.23	105	0.11	0.10	28	27	31	7.7	
		11.50	23	0.42	129	0.65	1.26	55	43	50	7.3	
VKK	Brummerspruit below Ermelo 26°30'49.51"S 29°54'27.37"E	16.53	37	0.42	200	0.51	1.73	96	80	70	7.4	
		35.50	36	0.31	210	4.00	2.52	60	82	69	8.0	
		6.80	40	0.26	120	0.22	0.24	125	34	59	7.5	
VKR	Tweefontein @ Riverside 26°37'21.17"S 29°50'16.24"E	<0.2	13	0.42	127	1.68	0.28	38	28	54	7.1	
		8.40	37	0.30	200	1.85	0.88	90	32	69	7.4	
		20.33	45	0.36	230	1.34	1.84	75	35	77	7.5	
VK	Brummerspruit before Vaal River 26°46'51.26"S 29°48'23.51"E	0.27	29	0.29	135	1.10	0.10	74	30	50	7.3	
		5.17	33	0.54	197	2.28	1.77	44	40	62	7.4	
		0.15	13	0.37	95	0.93	0.14	52	26	36	7.3	
VAS	Vaal River above Standerton 26°51'18.56"S 29°41'51.61"E	0.32	32	0.45	170	4.00	0.08	71	22	55	7.7	
		0.20	25	0.28	135	0.57	0.10	53	25	45	7.3	
		<0.2	9	0.36	28	0.36	<0.2	37	23	26	7.2	
VGK	Geelklipspruit below Amersfoort 26°57'53.51"S 29°40'19.12"E	0.40	15	0.41	114	0.59	0.10	32	22	34	7.8	
		0.35	9	0.22	134	0.26	0.24	24	19	40	8.3	
		0.20	14	0.25	83	0.16	0.1	34	14	29	7.5	
VBB	Blesbokspruit below Bethal 26°34'2.11"S 29°26'41.21"E											No Flow
												No Flow
		0.20	22	0.38	150	0.10	0.1	94	36	54	7.9	
VBS	Blesbokspruit @ Skaapkraal 26°38'17.35"S 29°27'6.24"E	0.86	19	0.40	133	1.93	1.15	35	30	57	7.3	
		12.23	48	0.35	223	0.55	1.87	40	50	66	8.4	
		20.00	43	0.41	230	<0.1	1.90	38	22	71	7.5	
VB	Blesbokspruit @ Vaal River Confluence 26°49'57.05"S 29°30'32.95"E	0.20	16	0.37	91	0.40	0.78	21	34	36	7.4	
		<0.2	29	0.59	91	0.50	0.40	43	53	34	7.8	
		0.23	42	0.27	193	0.39	0.74	33	63	59	9.2	
ND-LEEU	Leeuspruit @ New Denmark Colliery 26°51'16.79"S 29°19'31.56"E	0.99	57	0.30	232	1.58	1.17	49	38	71	7.8	
		0.20	11	0.26	89	0.24	0.25	22	28	28	7.4	
		0.26	17	0.58	113	0.57	0.14	44	28	40	7.6	
VS	Vaal River @ Standerton 26°56'51.37"S 29°15'32.09"E	0.63	41	0.28	200	0.49	0.18	81	27	60	7.8	
		<0.2	54	0.38	208	<0.1	0.21	52	25	64	8.1	
		0.20	17	0.26	91	0.12	0.12	26	31	28	7.2	
S-BETHAL	Bethal Sewage Works 26°29'8.05"S 29°27'15.88"E	<0.2	23	0.70	88	0.88	<0.2	70	22	41	7.4	
		<0.2	91	0.55	153	1.20	<0.1	285	26	98	8.2	
		0.20	14	0.19	71	0.28	0.1	30	27	26	7.3	
S-ESW	Ermelo Sewage Works 26°30'42.84"S 29°57'51.11"E	<0.2	11	0.35	93	1.90	0.10	38	29	30	7.8	
		0.64	10	0.31	88	0.24	0.16	34	27	27	7.8	
		<0.1	31	0.22	84	0.86	0.34	70	17	27	7.8	
S-TUTU	Tutukani Sewage Works 26°47'36.70"S 29°17'30.43"E	0.20	11	0.40	91	0.37	0.10	25	23	42	7.1	
		<0.2	42	0.21	71	6.20	4.87	44	59	41	7.6	41103
		0.30	50	0.27	125	2.17	0.65	55	26	53	7.5	37904
S-ND-SOUTH	New Denmark Colliery - South Shaft 26°44'41.51"S 29°18'31.70"E	11.32	42	0.34	200	7.30	0.59	50	41	69	7.6	726
		23.00	75	0.27	230	0.42	2.00	78	45	79	7.50	2,948,100
		14.67	28	0.22	150	7.10	2.57	69	61	64	7.0	527770
S-TUTU	Tutukani Sewage Works 26°47'36.70"S 29°17'30.43"E	33.00	46	0.26	258	1.80	3.13	88	81	88	7.2	1032800
		35.67	48	0.37	255	<0.1	4.47	80	122	85	7.0	1812900
		24.00	65	0.20	225	0.1	1.30	95	175	82	7.1	1,678,830
S-TUTU	Tutukani Sewage Works 26°47'36.70"S 29°17'30.43"E	0.20	73	0.18	81	13.00	0.10	58	22	59	7.5	27,200
		<0.2	61	0.38	101	8.27	0.34	78	23	68	7.6	2
		<0.2	39	36.00	93	9.05	0.56	71	22	59	7.4	3587
S-ND-SOUTH	New Denmark Colliery - South Shaft 26°44'41.51"S 29°18'31.70"E	10.62	56	0.25	74	14.00	1.15	85	28	59	7.3	17
		2.00	85	0.28	113	10.35	1.30	69	39	76	7.5	549
		0.39	72	0.25	120	4.40	1.60	52	41	71	7.5	7,110

Sample Points	Sample Point Description	Ammonia	Chloride	Fluoride	M-Alkalinity	Nitrate	Phosphate	Sulphate	Chemical Oxygen Demand	Conductivity	pH	E. coli
Sewage Works Compliance (where applicable) to General Standard (GN 1191 Oct 1999)												
S-BETHAL	Bethal Sewage Works 26°29'8.05"S 29°27'15.88"E	<0.2	42	0.21	71	6.20	4.87	44	59	41	7.6	41103
		0.30	50	0.27	125	2.17	0.65	55	26	53	7.5	37904
		11.32	42	0.34	200	7.30	0.59	50	41	69	7.6	726
		23.00	35	0.27	183	0.42	2.00	41	45	79	7.5	2,948,100
S-ESW	Ermelo Sewage Works 26°30'42.84"S 29°57'51.11"E	14.67	28	0.22	150	7.10	2.57	69	61	64	7.0	527770
		33.00	46	0.26	258	1.80	3.13	88	81	88	7.2	1032800
		35.67	48	0.37	255	<0.1	4.47	80	122	85	7.0	1812900
		24.00	45	0.20	233	0.1	1.30	67	175	82	7.1	1,678,830
S-TUTU	Tutukani Sewage Works 26°47'36.70"S 29°17'30.43"E	<0.2	61	0.38	101	8.27	0.34	78	23	68	7.6	2
		<0.2	39	36.00	93	9.05	0.56	71	22	59	7.4	3587
		10.62	56	0.25	74	14.00	1.15	85	28	59	7.3	17
		0.20	45	0.18	97	13.00	0.10	80	22	59	7.5	27,200
S-ND-SOUTH	New Denmark Colliery - South Shaft 26°44'41.51"S 29°18'31.70"E	1.90	69	0.42	150	0.42	1.15	92	60	75	7.8	12741
		2.10	52	37.00	120	10.35	1.30	64	51	78	7.3	56285
		2.00	85	0.28	113	10.35	1.30	69	39	76	7.5	549
		0.39	64	0.25	110	4.40	1.60	90	41	71	7.5	7,110

Key

VE	Vaal River above Standerton	0.12	-	1 Apr 16 - 30 Jun 16
		0.12	-	1 July 16 - 30 Sept 16
		0.12	-	1 Oct 16 - 31 Dec 16
		0.12	-	1 Jan 17 - 31 Mar 17

Water Quality Guidelines

	-	Ideal
	-	Acceptable
	-	Tolerable
	-	Unacceptable

Sewage Works Compliance to General Standard (GN 1191 Oct 1999)			
Variables	Measured as	Acceptable Management Target	Unacceptable
Physical			
Conductivity	mS/m	<150	>=150
pH	pH units	5.5 - 9.5	< 5.5; >9.5
Organic			
Chemical Oxygen Demand (COD)**	mg/l	<75	>=75
Macro Elements			
Ammonia (NH ₄)	mg/l	<3	>=3
Fluoride (F)	mg/l	<1	>=1
Nitrate (NO ₃)	mg/l	<15	>=15
Phosphate (PO ₄)	mg/l	<10	>10
Bacteriological			
Faecal coliforms	counts/100ml	<1000	>=1000

** After removal of algae