



RAND WATER

Emfuleni Water Quality Report
1 Month

23 July 2020 to 21 August 2020

Date generated: 28 August 2020

							Descriptive Statistics		
Determinands	Measurement Units	Risks	SANS 241:2015 standard limits (1)	No of results	Required compliances to SANS 241:2015 spec(%)	Achieved compliances to SANS 241:2015 spec(%)	Mean	Standard Deviation	Mean + 3 Std deviations
Microbiological determinands									
<i>E. coli</i>	(mpn per 100 mL)	Acute health	Non-detect	101	99.0%	100%	0	0.00	0
Total Coliforms	(mpn per 100 mL)	Operational	≤ 10	101	95.0%	100%	0	0.00	0
Heterotrophic Plate Count	(cfu per 1 mL)	Operational	≤ 1000	101	95.0%	100%	0	0.65	2
<i>Cryptosporidium spp</i> (2)	(org / 10 Litre)	Acute health	Non-detect	17	99.0%	100%	0	0.00	0
<i>Giardia spp</i> (2)	(org / 10 Litre)	Acute health	Non-detect	17	99.0%	100%	0	0.00	0
Somatic Coliphages (2)	(count per 10 mL)	Operational	Non-detect	68	95.0%	100%	0	0.00	0
Physical and Aesthetic determinands									
Colour	(mg / L as Pt-Co)	Aesthetic	≤ 15	5	95.0%	100%	5.40	0.55	7.04
Conductivity	(mS / m)	Aesthetic	≤ 170	75	95.0%	100%	21.67	1.17	25.17
Total Dissolved Solids	(mg / L)	Aesthetic	≤ 1200	5	95.0%	100%	149.00	9.62	177.85
Turbidity	(NTU)	Operational	≤ 1	75	95.0%	100%	0.29	0.05	0.45
Turbidity	(NTU)	Aesthetic	≤ 5	75	95.0%	100%	0.29	0.05	0.45
pH	(pH units)	Operational	≥ 5 to ≤ 9.7	75	95.0%	100%	7.97	0.14	8.38
Chemical Properties: Macro determinands									
Ammonia	(mg / L as N)	Aesthetic	≤ 1.5	68	95.0%	100%	0.04	0.07	0.25
Chloride	(mg / L as Cl)	Aesthetic	≤ 300	1	95.0%	100%	12.00	n/a	12.00
Free chlorine	(mg / L as Cl ₂)	Chronic health	≤ 5	101	97.0%	100%	1.44	0.45	2.78
Monochloramine	(mg / L as Cl ₂)	Chronic health	≤ 4.1	n/a	97.0%	n/a	n/a	n/a	n/a
Fluoride	(mg / L as F)	Chronic health	≤ 1.5	1	97.0%	100%	0.20	n/a	0.20
Nitrate	(mg / L as N)	Acute health	≤ 11	74	99.0%	100%	0.52	0.04	0.65
Nitrite	(mg / L as N)	Acute health	≤ 0.9	73	99.0%	100%	0.02	0.01	0.04
Combined nitrate plus nitrite (3)	(mg / L as N)	Acute health	≤ 1	74	99.0%	100%	0.17	0.23	0.86
Residual disinfectant (4)	(mg / L as Cl ₂)	Operational	≥ 0.2	101	95.0%	100%	1.44	0.45	2.78
Sodium	(mg / L as Na)	Aesthetic	≤ 200	5	95.0%	100%	10.96	1.05	14.12
Sulphate	(mg / L as SO ₄)	Aesthetic	≤ 250	4	95.0%	100%	19.25	0.50	20.75
Sulphate	(mg / L as SO ₄)	Acute health	≤ 500	4	99.0%	100%	19.25	0.50	20.75
Zinc	(mg / L as Zn)	Aesthetic	≤ 5	5	95.0%	100%	0.02	0.00	0.02
Chemical Properties: Micro determinands									
Aluminium	(µg / L as Al)	Operational	≤ 300	5	95.0%	100%	32.20	16.10	80.50
Antimony	(µg / L as Sb)	Chronic health	≤ 20	2	97.0%	100%	0.60	0.00	0.60
Arsenic	(µg / L as As)	Chronic health	≤ 10	2	97.0%	100%	8.00	0.00	8.00
Barium	(µg / L as Ba)	Chronic health	≤ 700	5	97.0%	100%	43.00	3.94	54.81
Boron	(µg / L as B)	Chronic health	≤ 2400	5	97.0%	100%	10.60	2.55	18.26
Cadmium	(µg / L as Cd)	Chronic health	≤ 3	2	97.0%	100%	1.50	0.00	1.50
Chromium (Total)	(µg / L as Cr)	Chronic health	≤ 50	5	97.0%	100%	5.00	0.00	5.00
Copper	(µg / L as Cu)	Chronic health	≤ 2000	5	97.0%	100%	8.00	0.00	8.00
Cyanide (Recoverable)	(µg / L as CN)	Acute health	≤ 200	5	99.0%	100%	5.00	0.00	5.00
Iron	(µg / L as Fe)	Chronic health	≤ 2000	5	97.0%	100%	33.00	22.17	99.51
Iron	(µg / L as Fe)	Aesthetic	≤ 300	5	95.0%	100%	33.00	22.17	99.51
Lead	(µg / L as Pb)	Chronic health	≤ 10	2	97.0%	100%	8.00	0.00	8.00
Manganese	(µg / L as Mn)	Chronic health	≤ 400	5	97.0%	100%	3.10	0.22	3.77
Manganese	(µg / L as Mn)	Aesthetic	≤ 100	5	95.0%	100%	3.10	0.22	3.77
Mercury	(µg / L as Hg)	Chronic health	≤ 6	2	97.0%	100%	1.50	0.00	1.50
Nickel	(µg / L as Ni)	Chronic health	≤ 70	5	97.0%	100%	5.00	0.00	5.00
Selenium	(µg / L as Se)	Chronic health	≤ 40	2	97.0%	100%	8.00	0.00	8.00
Uranium	(µg / L as U)	Chronic health	≤ 30	2	97.0%	100%	0.50	0.00	0.50
Organic determinands									
Total Organic Carbon	(mg / L)	Chronic health	≤ 10	2	97.0%	100%	4.10	0.14	4.52
Phenols as C ₆ H ₅ OH	(µg / L)	Aesthetic	≤ 10	2	95.0%	100%	3.00	0.00	3.00
Chloroform - CHCl ₃	(µg / L)	Chronic health	≤ 300	9	97.0%	100%	15.22	7.71	38.35
Bromoform - CHBr ₃	(µg / L)	Chronic health	≤ 100	9	97.0%	100%	10.00	0.00	10.00
Dibromochloromethane - CHBr ₂ Cl	(µg / L)	Chronic health	≤ 100	9	97.0%	100%	10.00	0.00	10.00
Bromodichloromethane - CHBrCl ₂	(µg / L)	Chronic health	≤ 60	9	97.0%	100%	10.89	2.03	16.97
Combined trihalomethanes (5)	(µg / L)	Chronic health	≤ 1	9	97.0%	100%	0.21	0.09	0.47
Total Microcystin (2)	(µg / L)	Chronic health	≤ 1	17	97.0%	100%	0.31	0.00	0.31
For monitoring/reporting purposes only									
Calcium (6)	(mg / L as Ca)	Aesthetic	≤ 150	5	not applicable	100%	18.20	1.30	22.11
Hardness (7)	(mg / L as CaCO ₃)	Operational	≥ 20 to ≤ 200	5	not applicable	100%	70.80	4.92	85.56
Magnesium (6)	(mg / L as Mg)	Aesthetic	≤ 70	5	not applicable	100%	7.28	0.54	8.89
Potassium (6)	(mg / L as K)	Aesthetic	≤ 50	5	not applicable	100%	3.50	0.28	4.35
Rand Water Risk Determinands (RWRD) (6)									
Odour	TON	RWRD	≤ 2	8	not applicable	100%	1.00	0.00	1.00
Taste	FTN	RWRD	≤ 2	8	not applicable	100%	1.00	0.00	1.00

Risks	Required compliances to SANS 241: 2015 standard	Overall Compliances - SANS 241: 2015 standard
Acute health microbiological	99.0%	100%
Acute health chemical	99.0%	100%
Chronic health	97.0%	100%
Aesthetic	95.0%	100%
Operational	95.0%	100%

- Notes
- (1) Specification SANS 241 date of effect : 1 July 2016
 - (2) Measured at water treatment works exit points
 - (3) (NO₂/0.9 + NO₃/11)
 - (4) Residual disinfectant : Results from the chlorinated system = Free available chlorine
 - (5) (CHCl₃/300 + CHBr₃/100 + CHBr₂Cl/100 + CHBrCl₂/60)
 - (6) Customer request: Results not included in the risk indices compliance calculations and limits based on SANS 241:2006
 - (7) Customer request: Results not included in the risk indices compliance calculations and limits based on RW Internal Spec
- **** Determinands with no data are due to instrument breakdown****