



RAND WATER

Govan Mbeki Water Quality Report  
1 Month

22 May 2021 to 21 June 2021

Date generated: 13 July 2021

							Descriptive Statistics		
Determinands	Measurement Units	Risks	SANS 241:2015 standard limits (1)	No of results	Required compliances to SANS 241:2015 spec(%)	Achieved compliances to SANS 241:2015 spec(%)	Mean	Standard Deviation	Mean + 3 Std deviations
<b>Microbiological determinands</b>									
<i>E. coli</i>	(mpn per 100 mL)	Acute health	Non-detect	75	99.0%	100%	0	0.00	0
Total Coliforms	(mpn per 100 mL)	Operational	≤ 10	75	95.0%	100%	0	0.00	0
Heterotrophic Plate Count	(cfu per 1 mL)	Operational	≤ 1000	75	95.0%	100%	2	7.07	23
<i>Cryptosporidium spp</i> (2)	(org / 10 Litre)	Acute health	Non-detect	no data	99.0%	no data	.	no data	.
<i>Giardia spp</i> (2)	(org / 10 Litre)	Acute health	Non-detect	no data	99.0%	no data	.	no data	.
Somatic Coliphages (2)	(count per 10 mL)	Operational	Non-detect	64	95.0%	100%	0	0.00	0
<b>Physical and Aesthetic determinands</b>									
Colour	(mg / L as Pt-Co)	Aesthetic	≤ 15	7	95.0%	100%	7.57	1.99	13.54
Conductivity	(mS / m)	Aesthetic	≤ 170	74	95.0%	100%	23.45	2.43	30.75
Total Dissolved Solids	(mg / L)	Aesthetic	≤ 1200	7	95.0%	100%	159.29	11.70	194.39
Turbidity	(NTU)	Operational	≤ 1	74	95.0%	100%	0.31	0.05	0.47
Turbidity	(NTU)	Aesthetic	≤ 5	74	95.0%	100%	0.31	0.05	0.47
pH	(pH units)	Operational	≥ 5 to ≤ 9.7	74	95.0%	100%	7.75	0.13	8.14
<b>Chemical Properties: Macro determinands</b>									
Ammonia	(mg / L as N)	Aesthetic	≤ 1.5	74	95.0%	100%	0.21	0.11	0.56
Chloride	(mg / L as Cl)	Aesthetic	≤ 300	7	95.0%	100%	15.57	2.70	23.67
Free chlorine	(mg / L as Cl <sub>2</sub> )	Chronic health	≤ 5	75	97.0%	100%	0.09	0.14	0.51
Monochloramine	(mg / L as Cl <sub>2</sub> )	Chronic health	≤ 4.1	75	97.0%	100%	0.74	0.45	2.08
Fluoride	(mg / L as F)	Chronic health	≤ 1.5	7	97.0%	100%	0.34	0.13	0.73
Nitrate	(mg / L as N)	Acute health	≤ 11	74	99.0%	100%	0.70	0.13	1.08
Nitrite	(mg / L as N)	Acute health	≤ 0.9	74	99.0%	100%	0.11	0.12	0.47
Combined nitrate plus nitrite (3)	(mg / L as N)	Acute health	≤ 1	74	99.0%	100%	0.20	0.13	0.60
Residual disinfectant (4)	(mg / L as Cl <sub>2</sub> )	Operational	≥ 0.1	75	95.0%	100%	0.81	0.45	2.14
Sodium	(mg / L as Na)	Aesthetic	≤ 200	9	95.0%	100%	12.67	1.12	16.02
Sulphate	(mg / L as SO <sub>4</sub> )	Aesthetic	≤ 250	7	95.0%	100%	20.43	2.70	28.53
Sulphate	(mg / L as SO <sub>4</sub> )	Acute health	≤ 500	7	99.0%	100%	20.43	2.70	28.53
Zinc	(mg / L as Zn)	Aesthetic	≤ 5	9	95.0%	100%	0.02	0.00	0.02
<b>Chemical Properties: Micro determinands</b>									
Aluminium	(µg / L as Al)	Operational	≤ 300	9	95.0%	100%	50.00	0.00	50.00
Antimony	(µg / L as Sb)	Chronic health	≤ 20	7	97.0%	100%	0.30	0.00	0.30
Arsenic	(µg / L as As)	Chronic health	≤ 10	7	97.0%	100%	8.00	0.00	8.00
Barium	(µg / L as Ba)	Chronic health	≤ 700	9	97.0%	100%	44.56	2.19	51.11
Boron	(µg / L as B)	Chronic health	≤ 2400	9	97.0%	100%	11.67	2.06	17.85
Cadmium	(µg / L as Cd)	Chronic health	≤ 3	7	97.0%	100%	1.77	0.26	2.54
Chromium (Total)	(µg / L as Cr)	Chronic health	≤ 50	9	97.0%	100%	5.00	0.00	5.00
Copper	(µg / L as Cu)	Chronic health	≤ 2000	9	97.0%	100%	8.00	0.00	8.00
Cyanide (Recoverable)	(µg / L as CN)	Acute health	≤ 200	7	99.0%	100%	5.00	0.00	5.00
Iron	(µg / L as Fe)	Chronic health	≤ 2000	9	97.0%	100%	11.26	2.59	19.03
Iron	(µg / L as Fe)	Aesthetic	≤ 300	9	95.0%	100%	11.26	2.59	19.03
Lead	(µg / L as Pb)	Chronic health	≤ 10	7	97.0%	100%	8.00	0.00	8.00
Manganese	(µg / L as Mn)	Chronic health	≤ 400	9	97.0%	100%	3.76	0.62	5.61
Manganese	(µg / L as Mn)	Aesthetic	≤ 100	9	95.0%	100%	3.76	0.62	5.61
Mercury	(µg / L as Hg)	Chronic health	≤ 6	7	97.0%	100%	1.50	0.00	1.50
Nickel	(µg / L as Ni)	Chronic health	≤ 70	9	97.0%	100%	5.00	0.00	5.00
Selenium	(µg / L as Se)	Chronic health	≤ 40	7	97.0%	100%	8.00	0.00	8.00
Uranium	(µg / L as U)	Chronic health	≤ 30	7	97.0%	100%	0.14	0.02	0.21
<b>Organic determinands</b>									
Total Organic Carbon	(mg / L)	Chronic health	≤ 10	7	97.0%	100%	5.19	0.11	5.51
Phenols as C <sub>6</sub> H <sub>5</sub> OH	(µg / L)	Aesthetic	≤ 10	6	95.0%	100%	2.50	0.00	2.50
Chloroform - CHCl <sub>3</sub>	(µg / L)	Chronic health	≤ 300	7	97.0%	100%	100.86	11.94	136.67
Bromoform - CHBr <sub>3</sub>	(µg / L)	Chronic health	≤ 100	7	97.0%	100%	10.00	0.00	10.00
Dibromochloromethane - CHBr <sub>2</sub> Cl	(µg / L)	Chronic health	≤ 100	7	97.0%	100%	10.00	0.00	10.00
Bromodichloromethane - CHBrCl <sub>2</sub>	(µg / L)	Chronic health	≤ 60	7	97.0%	100%	22.71	2.87	31.32
Combined trihalomethanes (5)	(µg / L)	Chronic health	≤ 1	7	97.0%	100%	0.73	0.08	0.99
Total Microcystin (2)	(µg / L)	Chronic health	≤ 1	17	97.0%	100%	0.31	0.00	0.31
<b>For monitoring/reporting purposes only</b>									
Calcium (6)	(mg / L as Ca)	Aesthetic	≤ 150	9	not applicable	100%	17.56	0.73	19.74
Hardness (7)	(mg / L as CaCO <sub>3</sub> )	Operational	≥ 20 to ≤ 200	9	not applicable	100%	68.89	3.44	79.22
Magnesium (6)	(mg / L as Mg)	Aesthetic	≤ 70	9	not applicable	100%	7.20	0.63	9.10
Potassium (6)	(mg / L as K)	Aesthetic	≤ 50	9	not applicable	100%	4.61	0.20	5.20
<b>Rand Water Risk Determinands (RWRD) (6)</b>									
Odour	TON	RWRD	≤ 2	39	not applicable	100%	1.00	0.00	1.00
Taste	FTN	RWRD	≤ 2	39	not applicable	100%	1.00	0.00	1.00

Risks	Required compliances to SANS 241: 2015 standard	Overall Compliances - SANS 241: 2015 standard
Acute health microbiological	99.0%	100%
Acute health chemical	99.0%	100%
Chronic health	97.0%	100%
Aesthetic	95.0%	100%
Operational	95.0%	100%

Notes  
 (1) Specification SANS 241 date of effect : 1 July 2016  
 (2) Measured at water treatment works exit points  
 (3) (NO<sub>2</sub>/0.9 + NO<sub>3</sub>/11)  
 (4) Residual disinfectant : Results from the chloraminated system = Sum of Free and Monochloramine  
 (5) (CHCl<sub>3</sub>/300 + CHBr<sub>3</sub>/100 + CHBr<sub>2</sub>Cl/100 + CHBrCl<sub>2</sub>/60)  
 (6) Customer request: Results not included in the risk indices compliance calculations and limits based on SANS 241:2006  
 (7) Customer request: Results not included in the risk indices compliance calculations and limits based on RW Internal Spec  
 \*\*\*\* Determinands with no data are due to instrument breakdown\*\*\*\*