



RAND WATER

Merafong Water Quality Report
1 Month

23 July 2020 to 21 August 2020

Date generated: 28 August 2020

							Descriptive Statistics		
Determinands	Measurement Units	Risks	SANS 241:2015 standard limits (1)	No of results	Required compliances to SANS 241:2015 spec(%)	Achieved compliances to SANS 241:2015 spec(%)	Mean	Standard Deviation	Mean + 3 Std deviations
Microbiological determinands									
<i>E. coli</i>	(mpn per 100 mL)	Acute health	Non-detect	66	99.0%	100%	0	0.00	0
Total Coliforms	(mpn per 100 mL)	Operational	≤ 10	66	95.0%	100%	0	0.00	0
Heterotrophic Plate Count	(cfu per 1 mL)	Operational	≤ 1000	66	95.0%	100%	6	34.11	109
<i>Cryptosporidium spp</i> (2)	(org / 10 Litre)	Acute health	Non-detect	16	99.0%	100%	0	0.00	0
<i>Giardia spp</i> (2)	(org / 10 Litre)	Acute health	Non-detect	16	99.0%	100%	0	0.00	0
Somatic Coliphages (2)	(count per 10 mL)	Operational	Non-detect	64	95.0%	100%	0	0.00	0
Physical and Aesthetic determinands									
Colour	(mg / L as Pt-Co)	Aesthetic	≤ 15	5	95.0%	100%	6.00	1.00	9.00
Conductivity	(mS / m)	Aesthetic	≤ 170	61	95.0%	100%	22.10	1.64	27.02
Total Dissolved Solids	(mg / L)	Aesthetic	≤ 1200	5	95.0%	100%	141.00	2.24	147.71
Turbidity	(NTU)	Operational	≤ 1	61	95.0%	100%	0.29	0.05	0.43
Turbidity	(NTU)	Aesthetic	≤ 5	61	95.0%	100%	0.29	0.05	0.43
pH	(pH units)	Operational	≥ 5 to ≤ 9.7	61	95.0%	100%	8.00	0.12	8.37
Chemical Properties: Macro determinands									
Ammonia	(mg / L as N)	Aesthetic	≤ 1.5	59	95.0%	100%	0.36	0.12	0.73
Chloride	(mg / L as Cl)	Aesthetic	≤ 300	5	95.0%	100%	11.20	0.45	12.54
Free chlorine	(mg / L as Cl ₂)	Chronic health	≤ 5	66	97.0%	100%	0.11	0.17	0.62
Monochloramine	(mg / L as Cl ₂)	Chronic health	≤ 4.1	66	97.0%	100%	1.38	0.41	2.61
Fluoride	(mg / L as F)	Chronic health	≤ 1.5	5	97.0%	100%	0.20	0.00	0.20
Nitrate	(mg / L as N)	Acute health	≤ 11	64	99.0%	100%	0.58	0.06	0.76
Nitrite	(mg / L as N)	Acute health	≤ 0.9	56	99.0%	100%	0.02	0.05	0.17
Combined nitrate plus nitrite (3)	(mg / L as N)	Acute health	≤ 1	63	99.0%	100%	0.20	0.26	0.97
Residual disinfectant (4)	(mg / L as Cl ₂)	Operational	≥ 0.1	66	95.0%	100%	1.48	0.41	2.70
Sodium	(mg / L as Na)	Aesthetic	≤ 200	6	95.0%	100%	9.28	0.89	11.96
Sulphate	(mg / L as SO ₄)	Aesthetic	≤ 250	5	95.0%	100%	18.20	0.45	19.54
Sulphate	(mg / L as SO ₄)	Acute health	≤ 500	5	99.0%	100%	18.20	0.45	19.54
Zinc	(mg / L as Zn)	Aesthetic	≤ 5	6	95.0%	100%	0.02	0.01	0.05
Chemical Properties: Micro determinands									
Aluminium	(µg / L as Al)	Operational	≤ 300	6	95.0%	100%	29.17	10.21	59.79
Antimony	(µg / L as Sb)	Chronic health	≤ 20	5	97.0%	100%	0.60	0.00	0.60
Arsenic	(µg / L as As)	Chronic health	≤ 10	6	97.0%	100%	8.00	0.00	8.00
Barium	(µg / L as Ba)	Chronic health	≤ 700	6	97.0%	100%	39.83	4.31	52.76
Boron	(µg / L as B)	Chronic health	≤ 2400	6	97.0%	100%	6.73	1.40	10.92
Cadmium	(µg / L as Cd)	Chronic health	≤ 3	6	97.0%	100%	1.50	0.00	1.50
Chromium (Total)	(µg / L as Cr)	Chronic health	≤ 50	6	97.0%	100%	5.00	0.00	5.00
Copper	(µg / L as Cu)	Chronic health	≤ 2000	6	97.0%	100%	18.00	24.49	91.48
Cyanide (Recoverable)	(µg / L as CN)	Acute health	≤ 200	5	99.0%	100%	5.00	0.00	5.00
Iron	(µg / L as Fe)	Chronic health	≤ 2000	6	97.0%	100%	22.50	6.28	41.35
Iron	(µg / L as Fe)	Aesthetic	≤ 300	6	95.0%	100%	22.50	6.28	41.35
Lead	(µg / L as Pb)	Chronic health	≤ 10	6	97.0%	100%	8.00	0.00	8.00
Manganese	(µg / L as Mn)	Chronic health	≤ 400	6	97.0%	100%	3.00	0.00	3.00
Manganese	(µg / L as Mn)	Aesthetic	≤ 100	6	95.0%	100%	3.00	0.00	3.00
Mercury	(µg / L as Hg)	Chronic health	≤ 6	6	97.0%	100%	1.50	0.00	1.50
Nickel	(µg / L as Ni)	Chronic health	≤ 70	6	97.0%	100%	5.00	0.00	5.00
Selenium	(µg / L as Se)	Chronic health	≤ 40	6	97.0%	100%	8.00	0.00	8.00
Uranium	(µg / L as U)	Chronic health	≤ 30	5	97.0%	100%	0.50	0.00	0.50
Organic determinands									
Total Organic Carbon	(mg / L)	Chronic health	≤ 10	9	97.0%	100%	4.28	0.10	4.57
Phenols as C ₆ H ₅ OH	(µg / L)	Aesthetic	≤ 10	6	95.0%	100%	3.00	0.00	3.00
Chloroform - CHCl ₃	(µg / L)	Chronic health	≤ 300	7	97.0%	100%	28.14	3.24	37.85
Bromoform - CHBr ₃	(µg / L)	Chronic health	≤ 100	7	97.0%	100%	10.00	0.00	10.00
Dibromochloromethane - CHBr ₂ Cl	(µg / L)	Chronic health	≤ 100	7	97.0%	100%	10.00	0.00	10.00
Bromodichloromethane - CHBrCl ₂	(µg / L)	Chronic health	≤ 60	7	97.0%	100%	13.14	1.46	17.53
Combined trihalomethanes (5)	(µg / L)	Chronic health	≤ 1	7	97.0%	100%	0.33	0.04	0.45
Total Microcystin (2)	(µg / L)	Chronic health	≤ 1	16	97.0%	100%	0.31	0.00	0.31
For monitoring/reporting purposes only									
Calcium (6)	(mg / L as Ca)	Aesthetic	≤ 150	6	not applicable	100%	15.67	0.82	18.12
Hardness (7)	(mg / L as CaCO ₃)	Operational	≥ 20 to ≤ 200	6	not applicable	100%	61.67	3.27	71.46
Magnesium (6)	(mg / L as Mg)	Aesthetic	≤ 70	6	not applicable	100%	6.45	0.37	7.57
Potassium (6)	(mg / L as K)	Aesthetic	≤ 50	6	not applicable	100%	2.93	0.31	3.88
Rand Water Risk Determinands (RWRD) (6)									
Odour	TON	RWRD	≤ 2	25	not applicable	100%	1.00	0.00	1.00
Taste	FTN	RWRD	≤ 2	25	not applicable	100%	1.00	0.00	1.00

Risks	Required compliances to SANS 241: 2015 standard	Overall Compliances - SANS 241: 2015 standard
Acute health microbiological	99.0%	100%
Acute health chemical	99.0%	100%
Chronic health	97.0%	100%
Aesthetic	95.0%	100%
Operational	95.0%	100%

Notes
 (1) Specification SANS 241 date of effect : 1 July 2016
 (2) Measured at water treatment works exit points
 (3) (NO₂/0.9 + NO₃/11)
 (4) Residual disinfectant : Results from the chloraminated system = Sum of Free and Monochloramine
 (5) (CHCl₃/300 + CHBr₃/100 + CHBr₂Cl/100 + CHBrCl₂/60)
 (6) Customer request: Results not included in the risk indices compliance calculations and limits based on SANS 241:2006
 (7) Customer request: Results not included in the risk indices compliance calculations and limits based on RW Internal Spec
 **** Determinands with no data are due to instrument breakdown****