



RAND WATER
Midvaal Water Quality Report
1 Month

22 May 2021 to 21 June 2021

Date generated: 13 July 2021

							Descriptive Statistics		
Determinands	Measurement Units	Risks	SANS 241:2015 standard limits (1)	No of results	Required compliances to SANS 241:2015 spec(%)	Achieved compliances to SANS 241:2015 spec(%)	Mean	Standard Deviation	Mean + 3 Std deviations
Microbiological determinands									
<i>E. coli</i>	(mpn per 100 mL)	Acute health	Non-detect	219	99.0%	100%	0	0.00	0
Total Coliforms	(mpn per 100 mL)	Operational	≤ 10	219	95.0%	100%	0	0.00	0
Heterotrophic Plate Count	(cfu per 1 mL)	Operational	≤ 1000	219	95.0%	100%	2	30.13	93
<i>Cryptosporidium spp</i> (2)	(org / 10 Litre)	Acute health	Non-detect	no data	99.0%	no data	no data	no data	no data
<i>Giardia spp</i> (2)	(org / 10 Litre)	Acute health	Non-detect	no data	99.0%	no data	no data	no data	no data
Somatic Coliphages (2)	(count per 10 mL)	Operational	Non-detect	64	95.0%	100%	0	0.00	0
Physical and Aesthetic determinands									
Colour	(mg / L as Pt-Co)	Aesthetic	≤ 15	16	95.0%	100%	7.81	1.83	13.31
Conductivity	(mS / m)	Aesthetic	≤ 170	151	95.0%	100%	22.90	1.84	28.42
Total Dissolved Solids	(mg / L)	Aesthetic	≤ 1200	16	95.0%	100%	154.69	4.27	167.50
Turbidity	(NTU)	Operational	≤ 1	151	95.0%	99.34%	0.33	0.18	0.88
Turbidity	(NTU)	Aesthetic	≤ 5	151	95.0%	100%	0.33	0.18	0.88
pH	(pH units)	Operational	≥ 5 to ≤ 9.7	151	95.0%	100%	7.99	0.20	8.57
Chemical Properties: Macro determinands									
Ammonia	(mg / L as N)	Aesthetic	≤ 1.5	151	95.0%	100%	0.11	0.05	0.26
Chloride	(mg / L as Cl)	Aesthetic	≤ 300	16	95.0%	100%	16.44	1.55	21.08
Free chlorine	(mg / L as Cl ₂)	Chronic health	≤ 5	219	97.0%	100%	0.88	0.51	2.39
Monochloramine	(mg / L as Cl ₂)	Chronic health	≤ 4.1	n/a	97.0%	n/a	n/a	n/a	n/a
Fluoride	(mg / L as F)	Chronic health	≤ 1.5	16	97.0%	100%	0.40	0.04	0.51
Nitrate	(mg / L as N)	Acute health	≤ 11	151	99.0%	100%	0.54	0.10	0.83
Nitrite	(mg / L as N)	Acute health	≤ 0.9	151	99.0%	100%	0.03	0.01	0.06
Combined nitrate plus nitrite (3)	(mg / L as N)	Acute health	≤ 1	151	99.0%	100%	0.08	0.02	0.14
Residual disinfectant (4)	(mg / L as Cl ₂)	Operational	≥ 0.2	219	95.0%	92.24%	0.88	0.51	2.39
Sodium	(mg / L as Na)	Aesthetic	≤ 200	16	95.0%	100%	12.31	0.87	14.93
Sulphate	(mg / L as SO ₄)	Aesthetic	≤ 250	16	95.0%	100%	21.25	1.95	27.10
Sulphate	(mg / L as SO ₄)	Acute health	≤ 500	16	99.0%	100%	21.25	1.95	27.10
Zinc	(mg / L as Zn)	Aesthetic	≤ 5	16	95.0%	100%	0.02	0.02	0.09
Chemical Properties: Micro determinands									
Aluminium	(µg / L as Al)	Operational	≤ 300	16	95.0%	100%	52.06	8.25	76.81
Antimony	(µg / L as Sb)	Chronic health	≤ 20	16	97.0%	100%	0.30	0.00	0.30
Arsenic	(µg / L as As)	Chronic health	≤ 10	16	97.0%	100%	8.00	0.00	8.00
Barium	(µg / L as Ba)	Chronic health	≤ 700	16	97.0%	100%	40.44	3.22	50.11
Boron	(µg / L as B)	Chronic health	≤ 2400	16	97.0%	100%	11.17	2.03	17.25
Cadmium	(µg / L as Cd)	Chronic health	≤ 3	16	97.0%	100%	1.50	0.00	1.50
Chromium (Total)	(µg / L as Cr)	Chronic health	≤ 50	16	97.0%	100%	5.00	0.00	5.00
Copper	(µg / L as Cu)	Chronic health	≤ 2000	16	97.0%	100%	9.41	2.65	17.35
Cyanide (Recoverable)	(µg / L as CN)	Acute health	≤ 200	16	99.0%	100%	5.00	0.00	5.00
Iron	(µg / L as Fe)	Chronic health	≤ 2000	16	97.0%	100%	25.66	19.93	85.45
Iron	(µg / L as Fe)	Aesthetic	≤ 300	16	95.0%	100%	25.66	19.93	85.45
Lead	(µg / L as Pb)	Chronic health	≤ 10	16	97.0%	100%	8.00	0.00	8.00
Manganese	(µg / L as Mn)	Chronic health	≤ 400	16	97.0%	100%	3.00	0.00	3.00
Manganese	(µg / L as Mn)	Aesthetic	≤ 100	16	95.0%	100%	3.00	0.00	3.00
Mercury	(µg / L as Hg)	Chronic health	≤ 6	16	97.0%	100%	1.50	0.00	1.50
Nickel	(µg / L as Ni)	Chronic health	≤ 70	16	97.0%	100%	5.00	0.00	5.00
Selenium	(µg / L as Se)	Chronic health	≤ 40	16	97.0%	100%	8.00	0.00	8.00
Uranium	(µg / L as U)	Chronic health	≤ 30	16	97.0%	100%	0.12	0.02	0.17
Organic determinands									
Total Organic Carbon	(mg / L)	Chronic health	≤ 10	16	97.0%	100%	5.05	0.23	5.73
Phenols as C ₆ H ₅ OH	(µg / L)	Aesthetic	≤ 10	16	95.0%	100%	2.50	0.00	2.50
Chloroform - CHCl ₃	(µg / L)	Chronic health	≤ 300	26	97.0%	100%	64.38	21.95	130.23
Bromoform - CHBr ₃	(µg / L)	Chronic health	≤ 100	26	97.0%	100%	10.00	0.00	10.00
Dibromochloromethane - CHBr ₂ Cl	(µg / L)	Chronic health	≤ 100	26	97.0%	100%	10.00	0.00	10.00
Bromodichloromethane - CHBrCl ₂	(µg / L)	Chronic health	≤ 60	26	97.0%	100%	17.50	4.37	30.62
Combined trihalomethanes (5)	(µg / L)	Chronic health	≤ 1	26	97.0%	100%	0.51	0.15	0.97
Total Microcystin (2)	(µg / L)	Chronic health	≤ 1	17	97.0%	100%	0.31	0.00	0.31
For monitoring/reporting purposes only									
Calcium (6)	(mg / L as Ca)	Aesthetic	≤ 150	16	not applicable	100%	17.75	0.86	20.32
Hardness (7)	(mg / L as CaCO ₃)	Operational	≥ 20 to ≤ 200	16	not applicable	100%	70.56	2.90	79.26
Magnesium (6)	(mg / L as Mg)	Aesthetic	≤ 70	16	not applicable	100%	7.56	0.30	8.47
Potassium (6)	(mg / L as K)	Aesthetic	≤ 50	16	not applicable	100%	4.56	0.29	5.43
Rand Water Risk Determinands (RWRD) (6)									
Odour	TON	RWRD	≤ 2	22	not applicable	100%	1.00	0.00	1.00
Taste	FTN	RWRD	≤ 2	22	not applicable	100%	1.00	0.00	1.00

Risks	Required compliances to SANS 241: 2015 standard	Overall Compliances - SANS 241: 2015 standard
Acute health microbiological	99.0%	100%
Acute health chemical	99.0%	100%
Chronic health	97.0%	100%
Aesthetic	95.0%	100%
Operational	95.0%	98.27%

Notes
 (1) Specification SANS 241 date of effect : 1 July 2016
 (2) Measured at water treatment works exit points
 (3) (NO₂/0.9 + NO₃/11)
 (4) Residual disinfectant : Results from the chlorinated system = Free available chlorine
 (5) (CHCl₃/300 + CHBr₃/100 + CHBr₂Cl/100 + CHBrCl₂/60)
 (6) Customer request: Results not included in the risk indices compliance calculations and limits based on SANS 241:2006
 (7) Customer request: Results not included in the risk indices compliance calculations and limits based on RW Internal Spec
 **** Determinands with no data are due to instrument breakdown****