



RAND WATER
RandWest Water Quality Report
1 Month

22 May 2021 to 21 June 2021

Date generated: 13 July 2021

							Descriptive Statistics		
Determinands	Measurement Units	Risks	SANS 241:2015 standard limits (1)	No of results	Required compliances to SANS 241:2015 spec(%)	Achieved compliances to SANS 241:2015 spec(%)	Mean	Standard Deviation	Mean + 3 Std deviations
Microbiological determinands									
<i>E. coli</i>	(mpn per 100 mL)	Acute health	Non-detect	67	99.0%	100%	0	0.00	0
Total Coliforms	(mpn per 100 mL)	Operational	≤ 10	67	95.0%	100%	0	0.00	0
Heterotrophic Plate Count	(cfu per 1 mL)	Operational	≤ 1000	67	95.0%	100%	2	4.34	15
<i>Cryptosporidium spp</i> (2)	(org / 10 Litre)	Acute health	Non-detect	no data	99.0%	no data	.	no data	.
<i>Giardia spp</i> (2)	(org / 10 Litre)	Acute health	Non-detect	no data	99.0%	no data	.	no data	.
Somatic Coliphages (2)	(count per 10 mL)	Operational	Non-detect	64	95.0%	100%	0	0.00	0
Physical and Aesthetic determinands									
Colour	(mg / L as Pt-Co)	Aesthetic	≤ 15	3	95.0%	100%	11.33	1.15	14.80
Conductivity	(mS / m)	Aesthetic	≤ 170	67	95.0%	100%	24.13	2.20	30.74
Total Dissolved Solids	(mg / L)	Aesthetic	≤ 1200	3	95.0%	100%	180.00	8.66	205.98
Turbidity	(NTU)	Operational	≤ 1	67	95.0%	100%	0.32	0.05	0.46
Turbidity	(NTU)	Aesthetic	≤ 5	67	95.0%	100%	0.32	0.05	0.46
pH	(pH units)	Operational	≥ 5 to ≤ 9.7	67	95.0%	100%	7.87	0.13	8.25
Chemical Properties: Macro determinands									
Ammonia	(mg / L as N)	Aesthetic	≤ 1.5	67	95.0%	100%	0.35	0.10	0.66
Chloride	(mg / L as Cl)	Aesthetic	≤ 300	3	95.0%	100%	17.67	1.53	22.25
Free chlorine	(mg / L as Cl ₂)	Chronic health	≤ 5	67	97.0%	100%	0.08	0.03	0.18
Monochloramine	(mg / L as Cl ₂)	Chronic health	≤ 4.1	67	97.0%	100%	1.57	0.36	2.65
Fluoride	(mg / L as F)	Chronic health	≤ 1.5	3	97.0%	100%	0.52	0.00	0.52
Nitrate	(mg / L as N)	Acute health	≤ 11	67	99.0%	100%	0.64	0.13	1.03
Nitrite	(mg / L as N)	Acute health	≤ 0.9	67	99.0%	100%	0.04	0.05	0.18
Combined nitrate plus nitrite (3)	(mg / L as N)	Acute health	≤ 1	66	99.0%	100%	0.11	0.06	0.27
Residual disinfectant (4)	(mg / L as Cl ₂)	Operational	≥ 0.1	67	95.0%	100%	1.64	0.37	2.75
Sodium	(mg / L as Na)	Aesthetic	≤ 200	4	95.0%	100%	11.75	0.50	13.25
Sulphate	(mg / L as SO ₄)	Aesthetic	≤ 250	3	95.0%	100%	20.33	0.58	22.07
Sulphate	(mg / L as SO ₄)	Acute health	≤ 500	3	99.0%	100%	20.33	0.58	22.07
Zinc	(mg / L as Zn)	Aesthetic	≤ 5	4	95.0%	100%	0.02	0.01	0.06
Chemical Properties: Micro determinands									
Aluminium	(µg / L as Al)	Operational	≤ 300	4	95.0%	100%	50.00	0.00	50.00
Antimony	(µg / L as Sb)	Chronic health	≤ 20	3	97.0%	100%	0.30	0.00	0.30
Arsenic	(µg / L as As)	Chronic health	≤ 10	4	97.0%	100%	8.00	0.00	8.00
Barium	(µg / L as Ba)	Chronic health	≤ 700	4	97.0%	100%	42.25	1.50	46.75
Boron	(µg / L as B)	Chronic health	≤ 2400	4	97.0%	100%	11.00	0.00	11.00
Cadmium	(µg / L as Cd)	Chronic health	≤ 3	4	97.0%	100%	1.50	0.00	1.50
Chromium (Total)	(µg / L as Cr)	Chronic health	≤ 50	4	97.0%	100%	5.00	0.00	5.00
Copper	(µg / L as Cu)	Chronic health	≤ 2000	4	97.0%	100%	8.00	0.00	8.00
Cyanide (Recoverable)	(µg / L as CN)	Acute health	≤ 200	3	99.0%	100%	5.00	0.00	5.00
Iron	(µg / L as Fe)	Chronic health	≤ 2000	4	97.0%	100%	40.75	14.89	85.41
Iron	(µg / L as Fe)	Aesthetic	≤ 300	4	95.0%	100%	40.75	14.89	85.41
Lead	(µg / L as Pb)	Chronic health	≤ 10	4	97.0%	100%	8.00	0.00	8.00
Manganese	(µg / L as Mn)	Chronic health	≤ 400	4	97.0%	100%	3.00	0.00	3.00
Manganese	(µg / L as Mn)	Aesthetic	≤ 100	4	95.0%	100%	3.00	0.00	3.00
Mercury	(µg / L as Hg)	Chronic health	≤ 6	4	97.0%	100%	1.50	0.00	1.50
Nickel	(µg / L as Ni)	Chronic health	≤ 70	4	97.0%	100%	5.00	0.00	5.00
Selenium	(µg / L as Se)	Chronic health	≤ 40	4	97.0%	100%	8.00	0.00	8.00
Uranium	(µg / L as U)	Chronic health	≤ 30	3	97.0%	100%	0.11	0.01	0.13
Organic determinands									
Total Organic Carbon	(mg / L)	Chronic health	≤ 10	3	97.0%	100%	5.20	0.10	5.50
Phenols as C ₆ H ₅ OH	(µg / L)	Aesthetic	≤ 10	3	95.0%	100%	2.50	0.00	2.50
Chloroform - CHCl ₃	(µg / L)	Chronic health	≤ 300	4	97.0%	100%	99.50	4.04	111.62
Bromoform - CHBr ₃	(µg / L)	Chronic health	≤ 100	4	97.0%	100%	10.00	0.00	10.00
Dibromochloromethane - CHBr ₂ Cl	(µg / L)	Chronic health	≤ 100	4	97.0%	100%	10.00	0.00	10.00
Bromodichloromethane - CHBrCl ₂	(µg / L)	Chronic health	≤ 60	4	97.0%	100%	22.50	0.58	24.23
Combined trihalomethanes (5)	(µg / L)	Chronic health	≤ 1	4	97.0%	100%	0.71	0.03	0.78
Total Microcystin (2)	(µg / L)	Chronic health	≤ 1	17	97.0%	100%	0.31	0.00	0.31
For monitoring/reporting purposes only									
Calcium (6)	(mg / L as Ca)	Aesthetic	≤ 150	4	not applicable	100%	16.75	0.50	18.25
Hardness (7)	(mg / L as CaCO ₃)	Operational	≥ 20 to ≤ 200	4	not applicable	100%	67.00	2.00	73.00
Magnesium (6)	(mg / L as Mg)	Aesthetic	≤ 70	4	not applicable	100%	7.20	0.20	7.80
Potassium (6)	(mg / L as K)	Aesthetic	≤ 50	4	not applicable	100%	4.38	0.13	4.75
Rand Water Risk Determinands (RWRD) (6)									
Odour	TON	RWRD	≤ 2	35	not applicable	100%	1.00	0.00	1.00
Taste	FTN	RWRD	≤ 2	35	not applicable	100%	1.00	0.00	1.00

Risks	Required compliances to SANS 241: 2015 standard	Overall Compliances - SANS 241: 2015 standard
Acute health microbiological	99.0%	100%
Acute health chemical	99.0%	100%
Chronic health	97.0%	100%
Aesthetic	95.0%	100%
Operational	95.0%	100%

Notes
(1) Specification SANS 241 date of effect : 1 July 2016
(2) Measured at water treatment works exit points
(3) (NO₂/0.9 + NO₃/11)
(4) Residual disinfectant : Results from the chloraminated system = Sum of Free and Monochloramine
(5) (CHCl₃/300 + CHBr₃/100 + CHBr₂Cl/100 + CHBrCl₂/60)
(6) Customer request: Results not included in the risk indices compliance calculations and limits based on SANS 241:2006
(7) Customer request: Results not included in the risk indices compliance calculations and limits based on RW Internal Spec
**** Determinands with no data are due to instrument breakdown****