



RAND WATER
Thembisile Water Quality Report
1 Month

22 April 2021 to 21 May 2021

Date generated: 04 June 2021

							Descriptive Statistics		
Determinands	Measurement Units	Risks	SANS 241:2015 standard limits (1)	No of results	Required compliances to SANS 241:2015 spec(%)	Achieved compliances to SANS 241:2015 spec(%)	Mean	Standard Deviation	Mean + 3 Std deviations
Microbiological determinands									
<i>E. coli</i>	(mpn per 100 mL)	Acute health	Non-detect	13	99.0%	100%	0	0.00	0
Total Coliforms	(mpn per 100 mL)	Operational	≤ 10	13	95.0%	100%	0	0.00	0
Heterotrophic Plate Count	(cfu per 1 mL)	Operational	≤ 1000	13	95.0%	100%	1	1.21	4
<i>Cryptosporidium spp</i> (2)	(org / 10 Litre)	Acute health	Non-detect	no data	99.0%	no data	.	no data	.
<i>Giardia spp</i> (2)	(org / 10 Litre)	Acute health	Non-detect	no data	99.0%	no data	.	no data	.
Somatic Coliphages (2)	(count per 10 mL)	Operational	Non-detect	71	95.0%	100%	0	0.00	0
Physical and Aesthetic determinands									
Colour	(mg / L as Pt-Co)	Aesthetic	≤ 15	1	95.0%	100%	10.00	no data	10.00
Conductivity	(mS / m)	Aesthetic	≤ 170	13	95.0%	100%	23.15	2.44	30.49
Total Dissolved Solids	(mg / L)	Aesthetic	≤ 1200	1	95.0%	100%	160.00	no data	160.00
Turbidity	(NTU)	Operational	≤ 1	13	95.0%	100%	0.33	0.12	0.70
Turbidity	(NTU)	Aesthetic	≤ 5	13	95.0%	100%	0.33	0.12	0.70
pH	(pH units)	Operational	≥ 5 to ≤ 9.7	13	95.0%	100%	7.80	0.11	8.15
Chemical Properties: Macro determinands									
Ammonia	(mg / L as N)	Aesthetic	≤ 1.5	13	95.0%	100%	0.21	0.18	0.75
Chloride	(mg / L as Cl)	Aesthetic	≤ 300	1	95.0%	100%	16.00	no data	16.00
Free chlorine	(mg / L as Cl ₂)	Chronic health	≤ 5	13	97.0%	100%	0.07	0.01	0.11
Monochloramine	(mg / L as Cl ₂)	Chronic health	≤ 4.1	13	97.0%	100%	0.50	0.22	1.15
Fluoride	(mg / L as F)	Chronic health	≤ 1.5	1	97.0%	100%	0.44	no data	0.44
Nitrate	(mg / L as N)	Acute health	≤ 11	13	99.0%	100%	0.67	0.06	0.86
Nitrite	(mg / L as N)	Acute health	≤ 0.9	13	99.0%	100%	0.20	0.09	0.48
Combined nitrate plus nitrite (3)	(mg / L as N)	Acute health	≤ 1	12	99.0%	100%	0.28	0.11	0.60
Residual disinfectant (4)	(mg / L as Cl ₂)	Operational	≥ 0.1	13	95.0%	100%	0.54	0.25	1.27
Sodium	(mg / L as Na)	Aesthetic	≤ 200	2	95.0%	100%	11.50	0.71	13.62
Sulphate	(mg / L as SO ₄)	Aesthetic	≤ 250	1	95.0%	100%	18.00	no data	18.00
Sulphate	(mg / L as SO ₄)	Acute health	≤ 500	1	99.0%	100%	18.00	no data	18.00
Zinc	(mg / L as Zn)	Aesthetic	≤ 5	2	95.0%	100%	0.02	0.00	0.02
Chemical Properties: Micro determinands									
Aluminium	(µg / L as Al)	Operational	≤ 300	2	95.0%	100%	50.00	0.00	50.00
Antimony	(µg / L as Sb)	Chronic health	≤ 20	1	97.0%	100%	0.30	no data	0.30
Arsenic	(µg / L as As)	Chronic health	≤ 10	2	97.0%	100%	8.00	0.00	8.00
Barium	(µg / L as Ba)	Chronic health	≤ 700	2	97.0%	100%	36.00	1.41	40.24
Boron	(µg / L as B)	Chronic health	≤ 2400	2	97.0%	100%	5.55	0.35	6.61
Cadmium	(µg / L as Cd)	Chronic health	≤ 3	2	97.0%	100%	1.50	0.00	1.50
Chromium (Total)	(µg / L as Cr)	Chronic health	≤ 50	2	97.0%	100%	5.00	0.00	5.00
Copper	(µg / L as Cu)	Chronic health	≤ 2000	2	97.0%	100%	8.00	0.00	8.00
Cyanide (Recoverable)	(µg / L as CN)	Acute health	≤ 200	1	99.0%	100%	5.00	no data	5.00
Iron	(µg / L as Fe)	Chronic health	≤ 2000	2	97.0%	100%	29.50	28.99	116.47
Iron	(µg / L as Fe)	Aesthetic	≤ 300	2	95.0%	100%	29.50	28.99	116.47
Lead	(µg / L as Pb)	Chronic health	≤ 10	2	97.0%	100%	8.00	0.00	8.00
Manganese	(µg / L as Mn)	Chronic health	≤ 400	2	97.0%	100%	3.00	0.00	3.00
Manganese	(µg / L as Mn)	Aesthetic	≤ 100	2	95.0%	100%	3.00	0.00	3.00
Mercury	(µg / L as Hg)	Chronic health	≤ 6	2	97.0%	100%	1.50	0.00	1.50
Nickel	(µg / L as Ni)	Chronic health	≤ 70	2	97.0%	100%	5.00	0.00	5.00
Selenium	(µg / L as Se)	Chronic health	≤ 40	2	97.0%	100%	8.00	0.00	8.00
Uranium	(µg / L as U)	Chronic health	≤ 30	1	97.0%	100%	0.10	no data	0.10
Organic determinands									
Total Organic Carbon	(mg / L)	Chronic health	≤ 10	1	97.0%	100%	6.30	no data	6.30
Phenols as C ₆ H ₅ OH	(µg / L)	Aesthetic	≤ 10	1	95.0%	100%	2.50	no data	2.50
Chloroform - CHCl ₃	(µg / L)	Chronic health	≤ 300	1	97.0%	100%	81.00	no data	81.00
Bromoform - CHBr ₃	(µg / L)	Chronic health	≤ 100	1	97.0%	100%	10.00	no data	10.00
Dibromochloromethane - CHBr ₂ Cl	(µg / L)	Chronic health	≤ 100	1	97.0%	100%	10.00	no data	10.00
Bromodichloromethane - CHBrCl ₂	(µg / L)	Chronic health	≤ 60	1	97.0%	100%	17.00	no data	17.00
Combined trihalomethanes (5)	(µg / L)	Chronic health	≤ 1	1	97.0%	100%	0.55	no data	0.55
Total Microcystin (2)	(µg / L)	Chronic health	≤ 1	20	97.0%	100%	0.31	0.00	0.31
For monitoring/reporting purposes only									
Calcium (6)	(mg / L as Ca)	Aesthetic	≤ 150	2	not applicable	100%	16.50	0.71	18.62
Hardness (7)	(mg / L as CaCO ₃)	Operational	≥ 20 to ≤ 200	2	not applicable	100%	65.50	3.54	76.11
Magnesium (6)	(mg / L as Mg)	Aesthetic	≤ 70	2	not applicable	100%	7.10	0.57	8.80
Potassium (6)	(mg / L as K)	Aesthetic	≤ 50	2	not applicable	100%	4.15	0.49	5.63
Rand Water Risk Determinands (RWRD) (6)									
Odour	TON	RWRD	≤ 2	4	not applicable	100%	1.00	0.00	1.00
Taste	FTN	RWRD	≤ 2	4	not applicable	100%	1.00	0.00	1.00

Risks	Required compliances to SANS 241: 2015 standard	Overall Compliances - SANS 241: 2015 standard
Acute health microbiological	99.0%	100%
Acute health chemical	99.0%	100%
Chronic health	97.0%	100%
Aesthetic	95.0%	100%
Operational	95.0%	100%

Notes
(1) Specification SANS 241 date of effect : 1 July 2016
(2) Measured at water treatment works exit points
(3) (NO₂/0.9 + NO₃/11)
(4) Residual disinfectant : Results from the chloraminated system = Sum of Free and Monochloramine
(5) (CHCl₃/300 + CHBr₃/100 + CHBr₂Cl/100 + CHBrCl₂/60)
(6) Customer request: Results not included in the risk indices compliance calculations and limits based on SANS 241:2006
(7) Customer request: Results not included in the risk indices compliance calculations and limits based on RW Internal Spec
**** Determinands with no data are due to instrument breakdown****