



RAND WATER
Thembisile Water Quality Report
1 Month

22 September 2020 to 22 October 2020

Date generated: 06 November 2020

							Descriptive Statistics		
Determinands	Measurement Units	Risks	SANS 241:2015 standard limits (1)	No of results	Required compliances to SANS 241:2015 spec(%)	Achieved compliances to SANS 241:2015 spec(%)	Mean	Standard Deviation	Mean + 3 Std deviations
Microbiological determinands									
<i>E. coli</i>	(mpn per 100 mL)	Acute health	Non-detect	15	99.0%	100%	0	0.00	0
Total Coliforms	(mpn per 100 mL)	Operational	≤ 10	15	95.0%	100%	0	0.00	0
Heterotrophic Plate Count	(cfu per 1 mL)	Operational	≤ 1000	15	95.0%	100%	0	0.26	1
<i>Cryptosporidium spp</i> (2)	(org / 10 Litre)	Acute health	Non-detect	16	99.0%	100%	0	0.00	0
<i>Giardia spp</i> (2)	(org / 10 Litre)	Acute health	Non-detect	16	99.0%	100%	0	0.00	0
Somatic Coliphages (2)	(count per 10 mL)	Operational	Non-detect	90	95.0%	100%	0	0.00	0
Physical and Aesthetic determinands									
Colour	(mg / L as Pt-Co)	Aesthetic	≤ 15	1	95.0%	100%	6.00	no data	6.00
Conductivity	(mS / m)	Aesthetic	≤ 170	15	95.0%	100%	21.40	4.55	35.04
Total Dissolved Solids	(mg / L)	Aesthetic	≤ 1200	1	95.0%	100%	140.00	no data	140.00
Turbidity	(NTU)	Operational	≤ 1	15	95.0%	100%	0.25	0.02	0.30
Turbidity	(NTU)	Aesthetic	≤ 5	15	95.0%	100%	0.25	0.02	0.30
pH	(pH units)	Operational	≥ 5 to ≤ 9.7	15	95.0%	100%	8.12	0.21	8.74
Chemical Properties: Macro determinands									
Ammonia	(mg / L as N)	Aesthetic	≤ 1.5	15	95.0%	100%	0.40	0.11	0.72
Chloride	(mg / L as Cl)	Aesthetic	≤ 300	1	95.0%	100%	11.00	no data	11.00
Free chlorine	(mg / L as Cl ₂)	Chronic health	≤ 5	15	97.0%	100%	0.08	0.03	0.16
Monochloramine	(mg / L as Cl ₂)	Chronic health	≤ 4.1	15	97.0%	100%	1.65	0.13	2.06
Fluoride	(mg / L as F)	Chronic health	≤ 1.5	1	97.0%	100%	0.33	no data	0.33
Nitrate	(mg / L as N)	Acute health	≤ 11	15	99.0%	100%	0.59	0.15	1.03
Nitrite	(mg / L as N)	Acute health	≤ 0.9	15	99.0%	100%	0.03	0.01	0.05
Combined nitrate plus nitrite (3)	(mg / L as N)	Acute health	≤ 1	15	99.0%	100%	0.08	0.02	0.14
Residual disinfectant (4)	(mg / L as Cl ₂)	Operational	≥ 0.1	15	95.0%	100%	1.73	0.15	2.19
Sodium	(mg / L as Na)	Aesthetic	≤ 200	2	95.0%	100%	8.00	1.27	11.82
Sulphate	(mg / L as SO ₄)	Aesthetic	≤ 250	1	95.0%	100%	14.00	no data	14.00
Sulphate	(mg / L as SO ₄)	Acute health	≤ 500	1	99.0%	100%	14.00	no data	14.00
Zinc	(mg / L as Zn)	Aesthetic	≤ 5	2	95.0%	100%	0.02	0.00	0.02
Chemical Properties: Micro determinands									
Aluminium	(µg / L as Al)	Operational	≤ 300	2	95.0%	100%	50.00	0.00	50.00
Antimony	(µg / L as Sb)	Chronic health	≤ 20	1	97.0%	100%	0.60	no data	0.60
Arsenic	(µg / L as As)	Chronic health	≤ 10	2	97.0%	100%	8.00	0.00	8.00
Barium	(µg / L as Ba)	Chronic health	≤ 700	2	97.0%	100%	36.50	0.71	38.62
Boron	(µg / L as B)	Chronic health	≤ 2400	2	97.0%	100%	3.00	0.00	3.00
Cadmium	(µg / L as Cd)	Chronic health	≤ 3	2	97.0%	100%	1.50	0.00	1.50
Chromium (Total)	(µg / L as Cr)	Chronic health	≤ 50	2	97.0%	100%	5.00	0.00	5.00
Copper	(µg / L as Cu)	Chronic health	≤ 2000	2	97.0%	100%	8.00	0.00	8.00
Cyanide (Recoverable)	(µg / L as CN)	Acute health	≤ 200	1	99.0%	100%	5.00	no data	5.00
Iron	(µg / L as Fe)	Chronic health	≤ 2000	2	97.0%	100%	33.50	36.06	141.69
Iron	(µg / L as Fe)	Aesthetic	≤ 300	2	95.0%	100%	33.50	36.06	141.69
Lead	(µg / L as Pb)	Chronic health	≤ 10	2	97.0%	100%	8.00	0.00	8.00
Manganese	(µg / L as Mn)	Chronic health	≤ 400	2	97.0%	100%	4.50	2.12	10.86
Manganese	(µg / L as Mn)	Aesthetic	≤ 100	2	95.0%	100%	4.50	2.12	10.86
Mercury	(µg / L as Hg)	Chronic health	≤ 6	2	97.0%	100%	1.50	0.00	1.50
Nickel	(µg / L as Ni)	Chronic health	≤ 70	2	97.0%	100%	5.00	0.00	5.00
Selenium	(µg / L as Se)	Chronic health	≤ 40	2	97.0%	100%	8.00	0.00	8.00
Uranium	(µg / L as U)	Chronic health	≤ 30	1	97.0%	100%	0.50	no data	0.50
Organic determinands									
Total Organic Carbon	(mg / L)	Chronic health	≤ 10	1	97.0%	100%	3.70	no data	3.70
Phenols as C ₆ H ₅ OH	(µg / L)	Aesthetic	≤ 10	1	95.0%	100%	3.00	no data	3.00
Chloroform - CHCl ₃	(µg / L)	Chronic health	≤ 300	1	97.0%	100%	29.00	no data	29.00
Bromoform - CHBr ₃	(µg / L)	Chronic health	≤ 100	1	97.0%	100%	10.00	no data	10.00
Dibromochloromethane - CHBr ₂ Cl	(µg / L)	Chronic health	≤ 100	1	97.0%	100%	10.00	no data	10.00
Bromodichloromethane - CHBrCl ₂	(µg / L)	Chronic health	≤ 60	1	97.0%	100%	14.00	no data	14.00
Combined trihalomethanes (5)	(µg / L)	Chronic health	≤ 1	1	97.0%	100%	0.36	no data	0.36
Total Microcystin (2)	(µg / L)	Chronic health	≤ 1	16	97.0%	100%	0.31	0.00	0.31
For monitoring/reporting purposes only									
Calcium (6)	(mg / L as Ca)	Aesthetic	≤ 150	2	not applicable	100%	18.00	2.83	26.49
Hardness (7)	(mg / L as CaCO ₃)	Operational	≥ 20 to ≤ 200	2	not applicable	100%	56.00	21.21	119.64
Magnesium (6)	(mg / L as Mg)	Aesthetic	≤ 70	2	not applicable	100%	3.15	4.03	15.24
Potassium (6)	(mg / L as K)	Aesthetic	≤ 50	2	not applicable	100%	2.85	0.07	3.06
Rand Water Risk Determinands (RWRD) (6)									
Odour	TON	RWRD	≤ 2	4	not applicable	100%	1.00	0.00	1.00
Taste	FTN	RWRD	≤ 2	4	not applicable	100%	1.00	0.00	1.00

Risks	Required compliances to SANS 241: 2015 standard	Overall Compliances - SANS 241: 2015 standard
Acute health microbiological	99.0%	100%
Acute health chemical	99.0%	100%
Chronic health	97.0%	100%
Aesthetic	95.0%	100%
Operational	95.0%	100%

Notes
(1) Specification SANS 241 date of effect : 1 July 2016
(2) Measured at water treatment works exit points
(3) (NO₂/0.9 + NO₃/11)
(4) Residual disinfectant : Results from the chloraminated system = Sum of Free and Monochloramine
(5) (CHCl₃/300 + CHBr₃/100 + CHBr₂Cl/100 + CHBrCl₂/60)
(6) Customer request: Results not included in the risk indices compliance calculations and limits based on SANS 241:2006
(7) Customer request: Results not included in the risk indices compliance calculations and limits based on RW Internal Spec
**** Determinands with no data are due to instrument breakdown****